


C U S T O M E R Code : **25037**
Name :
Address : No.9, I-8 Rd.,
Map Ta Phut Industrial Estate,
Map Ta Phut, Muang, Rayong 21150
Site :
Location :
Test code : P894

Unit ID : **02LAC01AP101 BOILER FEED WATER PUMP**
Unit Type : Bearing Main-Journal
Unit Make : MHI TAKASAGO
Unit Model : MDG 344
Oil type / Viscosity : IDEMITSU DAPHNE SUPER TURBINE ISO 32
Oil System Capacity : 1150 Liters



Notes (Finding, Evaluation, Interpretation, Suggestion and Recommendation)

All wear conditions and wear tests appear in normal working range.
All oil conditions and oil tests appear in normal working range.
All contaminant conditions and contaminant levels appear in normal ranges.
No oil change recommended at this time, oil appears suitable for further use. Continue routine sampling interval.

Wasan C.

			Current Sample			Previous Sample			Baseline and Alarm Limit								
Condition History			Wear	Oil	Cont.	Wear	Oil	Cont.	Wear	Oil	Cont.	Alarm Limit					
			N	N	N	N	N	W	N	N	W	Alarm Limit Matrix -Set Name (Equipment type / oil type)					
Lab ID Bottle ID Date Sampled Oil Hours (Kms) Unit Hours (Kms) Oil Change Oil Added (Liters) Filters Hours (Kms)	Test Method	Result										B A S E L I N E	Bearing Main Daphne Turbine Oil 32 (BLCP)				
			249773	238387	235005												
			1034489	1027318	1024732												
			05-Mar-14	20-Nov-13	05-Nov-13												
			11520	9000	8304												
			13876	11356	10660												
Wear Condition												The New Oil (TNO)	Fine wear		Coarse wear		
Wear Element	Method	Unit	Fine(small) Wear	Coarse(large) Wear	Fine(small) Wear	Coarse(large) Wear	Fine(small) Wear	Coarse(large) Wear	Fine(small) Wear	Coarse(large) Wear	Fine(small) Wear	Coarse(large) Wear	U-Caution	U-Warning	U-Caution	U-Warning	
Iron	D-6595	PPM	0.0	0.4	0.5	4.5	0.5	0.8	0	>20	>35	>25	>30				
Chromium	D-6595	PPM	0.0	0.0	0.0	0.0	0.0	0.0	0	>1	>2	>2	>3				
Lead	D-6595	PPM	0.0	0.3	0.0	0.0	0.0	0.0	0	>2	>3	>6	>10				
Copper	D-6595	PPM	0.0	0.0	0.0	0.0	0.1	0.1	0	>5	>10	>10	>15				
Tin	D-6595	PPM	0.3	0.1	0.0	0.0	0.0	0.0	0	>2	>3	>3	>6				
Aluminum	D-6595	PPM	0.0	0.0	0.0	0.2	0.0	0.0	0	>1	>2	>2	>4				
Nickel	D-6595	PPM	0.0	0.0	0.0	0.0	0.0	0.2	0	>1	>2	>2	>3				
Silver	D-6595	PPM	0.0	0.0	0.0	0.0	0.0	0.0	0								
Molybdenum	D-6595	PPM	0.0	0.0	0.0	0.0	0.4	0.4	0								
Titanium	D-6595	PPM	0.0	0.0	0.0	0.0	0.0	0.7	0								
Oil Condition												TNO	L-Warning	L-Caution	U-Caution	U-Warning	
Viscosity @ 40°C	D-445	cSt	32.0		32.6		32.0		32.6	<29.3	<30.9	>34.2	>35.9				
Viscosity @ 100°C	D-445	cSt															
Oxidation	FTIR	Abs	7.6		7.4		6.7		7.2		>10.8	>14.4					
Nitration	FTIR	Abs	7.3		7.3		7.1		7.3		>10.9	>14.6					
TAN	D-974	mg KOH/g.	0.07		0.08		0.08		0.08		>0.18	>0.28					
TBN	D-4739	mg KOH/g.															
Contamination												TNO	U-Caution		U-Warning		
Water	T-H2O Check™	% (Wt.)	0.010		0.017		0.023		0.010		>0.05	>0.08					
Sodium	D-6595	PPM	0		0		0		0								
Silicon	D-6595	PPM	1.3	0.9	0.9	0.5	0.5	0.0	5	>10	>15	>10	>15				
Additive Element												TNO					
Boron	D-6595	PPM	0		0		0		0								
Magnesium	D-6595	PPM	0		0		0		0								
Calcium	D-6595	PPM	1		1		1		0								
Barium	D-6595	PPM	0		0		0		0								
Phosphorus	D-6595	PPM	246		252		211		310								
Zinc	D-6595	PPM	3	1	3	2	3	2	11								
Additional Test												TNO	L-Caution	L-Warning	U-Caution	U-Warning	
Flash Point	D-3828	°C															
Viscosity Index	D-2270																

Note: Alarm Limits are variable and dependent upon dataset size and to be used as general guideline.
 No Sign or **N** : NORMAL , C or **C** : CAUTION (first level warning limit) , W or **W** : Warning (second level warning limit)
 U-Caution : Upper CAUTION Level L-Caution : Lower CAUTION Level First Level Alarm_Alert Limit in Upper Level and/or Lower Level
 U-Warning : Upper WARNING Level L-Warning : Lower WARNING required Level Second Level Alarm_Alert Limit in Upper Level and/or Lower Level
 Baseline will be data of either "The new oil" or "Reference oil" or "Oil specification". TNO = The new oil , RO = Reference oil , OS = Oil Specification
 Accuracy of interpretation and recommendation are based on representatives sample and information supplied. No warranty is expressed or implied for this report.



C Code : 25037
 U Name :
 S
 T
 O
 M
 E
 R
 Address : No.9, I-8 Rd.,
 Map Ta Phut Industrial Estate,
 Map Ta Phut, Muang, Rayong 21150
 Site :
 Location :
 Test code : P894

Unit ID : 02LAC01AP101 BOILER FEED WATER PUMP
 Unit Type : Bearing Main-Journal
 Unit Make : MHI TAKASAGO
 Unit Model : MDG 344
 Oil type / Viscosity : IDEMITSU DAPHNE SUPER TURBINE ISO 32
 Oil System Capacity : 1150 Liters

Notes (Finding, Evaluation, Interpretation, Suggestion and Recommendation)


Particle count shows oil cleanliness level acceptable.

Lab ID	Current Sample		Previous Sample				Particle Count				
	Bottle ID	249773	1034489	238387	1027318	235005	1024732	NAS 1638 ISO 4406			
Date Sampled	05-Mar-14	11520	20-Nov-13	9000	05-Nov-13	8304	BASELINE Alarm Limit Bearing Main Daphne Turbine Oil 32 (BLCP)				
Oil Hours (Kms)	13876	11520	11356	9000	10660	8304					
Unit Hours (Kms)	13876	11520	11356	9000	10660	10660					
Oil Change											
Oil Added (Liters)											
Filters Hours (Kms)											
Contamination											
Particle Count NAS 1638 System Standard											
Particle Size Range	No. of Particles / 100ml.	Class	No. of Particles / 100ml.	Class	No. of Particles / 100ml.	Class	Class	No. of Particles / 100ml.	Class	No. of Particles / 100ml.	Class
Particle Size 5-15 microns	15,400	6	64,400	9 W	134,000	10 W		>16000	7	>32000	8
Particle Size 15-25 microns	1,400	5	5,900	8 W	12,200	9 W		>2850	7	>5700	8
Particle Size 25-50 microns	400	6	1,700	8 W	3,500	9 W		>506	7	>1012	8
Particle Size 50-100 microns	<100	5	100	7	300	8					
Particle Size >100 microns	<100	3	<100	6	<100	7					
Particle Count ISO 4406:1999 System Standard											
Particle Size Range	No. of Particles / ml.	Class	No. of Particles / ml.	Class	No. of Particles / ml.	Class	Class	No. of Particles / ml.	Class	No. of Particles / ml.	Class
Particle Size > 4 microns	461	16	1,933	18	4,020	19					
Particle Size > 6 microns	129	14	541	16	1,125	17					
Particle Size > 14 microns	18	11	76	13	158	14					
ISO 4406 Class Rating	16 / 14 / 11		18 / 16 / 13		19 / 17 / 14						




C Code : 25037
 U Name : .
 T Address : No.9, I-8 Rd.,
 O Map Ta Phut Industrial Estate,
 M Map Ta Phut, Muang, Rayong 21150
 E Site :
 R Location :
 Test code : P894

Unit ID : 02LAC01AP101 BOILER FEED WATER PUMP
 Unit Type : Bearing Main-Journal
 Unit Make : MHI TAKASAGO
 Unit Model : MDG 344
 Oil type / Viscosity : IDEMITSU DAPHNE SUPER TURBINE ISO 32
 Oil System Capacity : 1150 Liters



C Code : 25037
 U Name :
 S
 T
 O Address : No.9, I-8 Rd.,
 M Map Ta Phut Industrial Estate,
 E Map Ta Phut, Muang, Rayong 21150
 R
 Site :
 Location :
 Test code : P894

Unit ID : 02LAC01AP101 BOILER FEED WATER PUMP
 Unit Type : Bearing Main-Journal
 Unit Make : MHI TAKASAGO
 Unit Model : MDG 344
 Oil type / Viscosity : IDEMITSU DAPHNE SUPER TURBINE ISO 32
 Oil System Capacity : 1150 Liters



C Code : 25037
 U Name :
 S Address : No.9, I-8 Rd.,
 T Map Ta Phut Industrial Estate,
 O Map Ta Phut, Muang, Rayong 21150
 M Site :
 E Location :
 R Test code : P894

E Unit ID : 02LAC01AP101 BOILER FEED WATER PUMP
 O Unit Type : Bearing Main-Journal
 I Unit Make : MHI TAKASAGO
 P Unit Model : MDG 344
 M Oil type / Viscosity : IDEMITSU DAPHNE SUPER TURBINE ISO 32
 E
 R Oil System Capacity : 1150 Liters

